



Neschen Coating GmbH
Hans-Neschen-Straße
31675 Bückeburg
Germany

Your message - reference

-

our reference

JW/2986

Gent

2024-08-28

Certification report 24/2986

1. Description of the product:

Product type	Self-adhesive decorative wallcovering consisting of a PE-paper backing coated with water-based acrylate adhesive on the reverse side and a PVC film finish
Total mass	155 g/m ²
Thickness	0.1 mm

2. Test results:

EN ISO 11925-2 (exposure=30s)	EN 13823
-------------------------------	----------

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB

addressee

Neschen Coating GmbH

our reference

JW/2986

Gent

2024-08-28

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows according EN 13501-1:2018:

C – s1, d0

if mounted over a plasterboard 13mm 700 kg/m³ or to substrates having a Euroclass A2-s1,d0 or A1 which density is superior to 525kg/m³

The evaluation of this properties is based on evaluation scheme specified in EN 13501-1:2019: Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests.

Products falls under system 3 of assessment and verification of constancy of performance like declared by the manufacturer.

Related commercial names to this product group

Solvoprint performance wall-grip

The obtained classification is based on the next test reports

CREPIM: DO-24-6259\A-R1 dd 07-08-2024

Validity of the certificate

06-08-2029

Jo Wynendaele, PhD

Consultant Floor and Wall Coverings

